


Augmented Care Group Report for Water Safety Group planned for May 2024

Updated version following as the May WSUG was

Date of report	11.06.2024
Completed by:	Justine Boyle, Lead Nurse IPC
Date of last Augmented Care meeting	11.06.2024 (Chair: Justine Boyle)
Key items discussed/ actions	<ul style="list-style-type: none"> • Terms of Reference no change since the previous WSUG (see below) <div style="text-align: center;">  <p>Augmented Care TORs - final June 20</p> </div> <ul style="list-style-type: none"> • Most clinical areas were represented at the meeting. <i>Key points of note were as follows:</i> <ul style="list-style-type: none"> ○ Several service areas reported ongoing review of remedial works being carried out due to detection of legionella/ pseudomonas from outlets (PICU, NICU, BCH 6N, CSICU). ○ NICU: The Water Reduced Neonatal Unit (WRNU) Task and Finish Group have considered several options for review; the sub-group have devised risk assessments against each option. No quorum for the Task and Finish Group on two occasions to agree on the risk rating of the risk assessments. ○ Installation of self-flushing taps commencing within RVH Level 3 Dialysis Unit. ○ Reminder to all areas to undertake their Annual MDT Water Risk Assessments.
Date of next Augmented Care meeting	05 th September 2024