BHSCT Hydrotherapy Pool Report
01/09/2023 - 31/12/2023

Pool Location	Dates outside acceptable range	Abnormal Reading Specify	Action Taken	Date resolved	Comments
Daily Readings					
Mitre MPH	2/9/23 7/9/23 8/9/23 11/9/23 12/9/23 18/9/23 19/9/23 21/9/23 9/10/23 10/10/23 13/10/23 20/10/23 23/10/23 29/11/23 7/12/23	Cl 2.48 PH 7.18 Cl 1.93 Cl 2.21 Cl 2.16 Cl 2.42 Cl 1.91-2.34 Cl 5.00 Cl 2.40 AM Cl 2.21 PM PH 7.07 Cl 2.34 PH 7.89 PH 7.69 AM PH 7.01 PM Cl 2.24 Cl >5.0	Retest 2.60 Retest 7.49 Retest 2.54 Retest 2.39 Retest 2.40 Retest 2.40 Pools cancelled Retest 4.71 Retest 2.79 Retest 2.60 Retest 7.15 Retest 2.83 Retest 7.56 Retest 7.60 Retest 7.35 Retest 2.55 Retest 4.91	2/9/23 7/9/23 8/9/23 11/9/23 12/9/23 18/9/23 20/9/23 21/9/23 9/10/23 9/10/23 10/10/23 13/10/23 20/10/23 23/10/23 29/11/23 7/12/23	19/9 Estates informed fault at pump room dosing system 9/10/23 Estates informed us water tank level was low
Level 3 RVH	0				
RBHSC	26/10/23 30/11/23 11/12/23	Ph- 7.7 Ph – 7.7 Ph – 7.8	Resolved pm Resolved pm Resolved pm	26/10/23 30/11/23 11/12/23	
Microbiology Reports					
Mitre MPH	4/10/23 12/10/23 18/10/23 13/12/23 21/12/23	Sample arrived no form Aerobic level 3 Sample arrived late Aerobic level 3 Arrived late			Resent 9/10/23 Still satisfactory Test was carried out Still satisfactory Resent 27/12/23

Level 3 RVH	0				
RBHSC	28/09/23 27/11/23	Unsatisfactory sample (pseud) Unsatisfactory sample (aerobic)	Pool closed, pool area cleaned, estates contacted, sample resent Pool closed, pool area cleaned, estates contacted, sample resent	02/10/23 04/12/23	
Environmental Readings					
Mitre MPH	0				
Level 3 RVH	0				
RBHSC	12/09/23 14/09/23 15/09/23 18/09/23 19/09/23 21/09/23 22/09/23 16/09/23 21/09/23 29/11/23 30/11/23 01/12/23 04/12/23 06/12/23 11/12/23 12/12/23 13/12/23 19/12/23 20/12/23 21/12/23	22°C 24°C 24°C 23°C 21°C 24°C 23°C 24°C 24°C 24°C 24°C 23°C 24°C 23°C 24°C 24°C 24°C 24°C 24°C 22°C	Fans turned off. Pool cover removed approx. 20 mins before session so would bring the air temp up to acceptable levels Estates contacted	20/09/23 20/09/23 20/09/23 20/09/23 20/09/23 25/09/23 25/09/23 16/09/23 22/09/23 07/12/23 07/12/23 07/12/23 07/12/23 07/12/23 14/12/23 14/12/23 14/12/23 ongoing	

	22/12/23 27/12/23 28/12/23 29/12/23	22.5°C 24.5°C 24.5°C 23°C	regarding temp in the pool area – pool originally had no pool cover so heated the area- air temp only problem in winter with pool cover on.		
Other Incidents					
Mitre MPH	20/12/23				New dosing pump fitted
Level 3 RVH					
RBHSC					

FFS Outline report:

Chemical Testing

Site	Total number of results outside normal limits	
MPH	**16**	
RVH Level 3	**0**	
RBHSC	**3**	

Microbiological testing :(weekly)

Site	Total number of samples per site	Total number of results outside normal limits	Percentage of results outside normal limits
MPH	**13**	**0**	
RVH Level 3	**15**	**0**	
RBHSC	**17**	**2**	**11.76%**